

May 20, 2025

Addendum No. 02

File Reference Number: RFP 2025 018

Title: North Bay Paint Shop Roof Upgrade

RE: Clarifications/Questions

Please refer to the following information/clarification:

Item 1: Part 3 - RFP Specifications - Schedule 3-A-2 - Technical Specifications - Specification Section 07 52 00 - 1.2 Summary

Specification Requirements: Additional wood blocking is to be added to achieve perimeter parapet detail that is a minimum of 8 inches from the finished height of the newly installed roofing assembly.

Answer: Change: Existing perimeter parapet detail height is to remain as existing specifically in the area of the roof access platform and large gas line. The existing parapet detail height is to remain as existing 12 inches from the roof access platform on the south side, extending to the Northwest corner adjacent to the roof access platform and gas line. Doing so will eliminate the need to uninstall and reinstall both the roof access platform and large gas line.

This Addendum hereby forms part of the RFP.

Regards,

Nicole Laplante
Procurement Contracts Specialist
nicole.laplante@ontarionorthland.ca