



555 Oak Street East
North Bay, Ontario
P1B 8L3

555, rue Oak Est
North Bay (Ontario)
P1B 8L3

Tel: 1-800-363-7512
www.ontarionorthland.ca

June 30, 2026

Addendum No. 01

File Reference Number: RFP 2026 045

Title: Cochrane Outdoor Electrical Distribution Upgrades

RE: Clarifications/Questions

CLARIFICATIONS/QUESTIONS:

Item 1: In order to decrease downtime onsite, would ONTC advise whether supplying a new, pre-fabricated, fully enclosed switchgear unit would be accepted?

Answer: ONTC advises that proponents may provide optional pricing for this item. Any new, pre-fabricated, fully enclosed switchgear unit shall match the functionality and key features of the existing unit, including, but not limited to, a walk-in enclosure and rack mount pull out breakers to facilitate maintenance.

Item 2: Would ONTC confirm whether the supply of an onsite spare breaker would be required?

Answer: Yes. ONTC advises that proponents shall include an additional onsite spare breaker within the scope of work. An 800 Amp frame breaker shall be supplied and installed in the designated spare compartment.

Item 3: Would ONTC advise whether proponents are required to upgrade the ground fault protection and relocate the controls to outside the switchgear room in order to allow for safer operation of the breakers?

Answer: Yes. ONTC advises that proponents shall include the addition of ground fault protection within the scope of work if such protection is not already incorporated into the proposed retrofit breakers. Proponents shall also identify and detail any breaker controls they propose to relocate outside the switchgear room to improve operational safety.

This Addendum hereby forms part of the RFP.

Regards,

Nicole Laplante
Procurement Contracts Specialist
nicole.laplante@ontarionorthland.ca