

October 15, 2026

Addendum No. 02

File Reference Number: RFP 2026 075

Title: Driveway Relocation and Crossing Closure Project

RE: Clarifications/Questions

QUESTIONS:

Item 1: If ONTC is not supplying the 450mm culvert what material shall the culvert be?

Answer: The Contractor shall supply the 450mm culvert. The culvert material may be either corrugated steel pipe (CSP) or high-density polyethylene (HDPE), provided it meets the requirements of the RFP Documents.

Item 2: Is ONTC supplying the 750mm Culvert? If no, what material will the culvert be?

Answer: No, ONTC will not be supplying the 750mm culvert. The Contractor shall supply the 750mm culvert. The culvert material may be either corrugated steel pipe (CSP) or high-density polyethylene (HDPE), provided it meets the requirements of the RFP Documents.

Item 3: Can a new Schedule A be provided to reflect the changes in Addendum No. 01?

Answer: Yes. A revised Schedule A reflecting the changes incorporated through Addendum No. 01 has been provided as a separate attachment to this Addendum and supersedes the previously issued Schedule A.

This Addendum hereby forms part of the RFP.

Regards,

Brinda Ranpura
Procurement Contracts Specialist
brinda.ranpura@ontarionorthland.ca